

# 2019 Annual Drinking Water Quality Report

## Toscana Subdivision (PWS ID# 3644157)

We are pleased to present to you this year's Annual Water Quality Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. Our water source is groundwater from wells drawing from the Floridan aquifer. The method of treatment is chlorination for disinfection.

In 2019 the Department of Environmental Protection performed a Source Water Assessment on our system and a search of the data sources indicated one potential source of contamination near our wells with a low susceptibility level. The assessment results are available on the FDEP Source Water Assessment and Protection Program website at [www.dep.state.fl.us/swapp](http://www.dep.state.fl.us/swapp)

This report shows our water quality results and what they mean. If you have any questions about this report or concerning your water utility, please contact the Toscana Subdivision at (386) 846-5098. We encourage our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings. They are generally held on the first Tuesday of each month at the Geneva Community Center.

The Toscana Subdivision routinely monitors for contaminants in your drinking water according to Federal and State laws, rules, and regulations. Except where indicated otherwise, this report is based on the results of our monitoring for the period of January 1 to December 31, 2019. Data obtained before January 1, 2019 and presented in this report are from the most recent testing done in accordance with the laws, rules, and regulations.

In the table below, you may find unfamiliar terms and abbreviations. To help you better understand these terms we have provided the following definitions:

- **Maximum Contaminant Level or MCL:** The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
- **Maximum Contaminant Level Goal or MCLG:** The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
- **Action Level (AL):** The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.
- **Maximum residual disinfectant level or MRDL:** The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
- **Maximum residual disinfectant level goal or MRDLG:** The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
- **Million fibers per liter (MFL):** measure of the presence of asbestos fibers that are longer than 10 micrometers
- **Parts per billion (ppb) or Micrograms per liter ( $\mu\text{g}/\text{l}$ ):** one part by weight of analyte to 1 billion parts by weight of the water sample.
- **Parts per million (ppm) or Milligrams per liter ( $\text{mg}/\text{l}$ ):** one part by weight of analyte to 1 million parts by weight of the water sample.
- **Picocurie per liter (pCi/L):** measure of the radioactivity in water.
- **Treatment Technique (TT):** A required process intended to reduce the level of a contaminant in drinking water.

## WATER QUALITY TEST RESULTS

<b>Radioactive Contaminants</b>							
<b>Contaminant and Unit of Measurement</b>	<b>Dates of sampling (mo./yr.)</b>	<b>MCL Violation Y/N</b>	<b>Level Detected</b>	<b>Range of Results</b>	<b>MCLG</b>	<b>MCL</b>	<b>Likely Source of Contamination</b>
Radium 226 + 228 or combined radium (pCi/L)	12/18	N	0.744	N/A	0	5	Erosion of natural deposits
Alpha emitters (pCi/L)	12/18	N	2.98	N/A	0	15	Erosion of natural deposits

<b><i>Inorganic Contaminants</i></b>							
<b><i>Contaminant and Unit of Measurement</i></b>	<b><i>Dates of sampling (mo./yr.)</i></b>	<b><i>MCL Violation Y/N</i></b>	<b><i>Level Detected</i></b>	<b><i>Range of Results</i></b>	<b><i>MCLG</i></b>	<b><i>MCL</i></b>	<b><i>Likely Source of Contamination</i></b>
Nitrate (as Nitrogen) (ppm)	4/18	N	0.025	N/A	10	10	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits
<b><i>Disinfectant or Contaminant and Unit of Measurement</i></b>	<b><i>Dates of sampling (mo./yr.)</i></b>	<b><i>MCL or MRDL Violation Y/N</i></b>	<b><i>Level Detected</i></b>	<b><i>Range of Results</i></b>	<b><i>MCLG or MRDLG</i></b>	<b><i>MCL or MRDL</i></b>	<b><i>Likely Source of Contamination</i></b>
Chlorine (ppm)	1/19-12/19	N	0.8	0.4-0.8	MRDLG = 4	MRDL = 4.0	Water additive used to control microbes
Haloacetic Acids (HAA5) (ppb)	12/18	N	15.2	N/A	NA	MCL = 60	By-product of drinking water disinfection
TTHM [Total trihalomethanes] (ppb)	12/18	N	62.1	N/A	NA	MCL = 80	By-product of drinking water disinfection

<b><i>Lead and Copper (Tap Water)</i></b>							
<b><i>Contaminant and Unit of Measurement</i></b>	<b><i>Dates of sampling (mo./yr.)</i></b>	<b><i>AL Exceeded (Y/N)</i></b>	<b><i>90th Percentile Result</i></b>	<b><i>No. of sampling sites exceeding the AL</i></b>	<b><i>MCLG</i></b>	<b><i>AL (Action Level)</i></b>	<b><i>Likely Source of Contamination</i></b>
Copper (tap water) (ppm)	7/19	N	0.956	0	1.3	1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
Lead (tap water) (ppb)	7/19	N	0.0076	0	0	15	Corrosion of household plumbing systems, erosion of natural deposits

Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- (A) Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- (B) Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- (C) Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- (D) Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems.
- (E) Radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, the EPA prescribes regulations, which limit the amount of certain contaminants in water provided by public water systems. The Food and Drug Administration (FDA) regulations establish limits for contaminants in bottled water, which must provide the same protection for public health. Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/Center for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbiological contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

*Thank you for allowing us to continue providing your family with clean, quality water this year. In order to maintain a safe and dependable water supply, we sometimes need to make improvements that will benefit all of our customers. These improvements are sometimes reflected as rate structure adjustments. Thank you for understanding.*

*We at the Toscana Subdivision would like you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. If you have any questions or concerns about the information provided, please feel free to call any of the numbers listed.*